



# CERTIFICATE OF INSPECTION

**CUSTOMERS NAME AND ADDRESS**

**WHITECHAPEL MISSION  
212 WHITECHAPEL ROAD  
LONDON  
E1 1BJ**

<u>TYPE OF FIRE EXTINGUISHER</u>	<u>QUANTITY</u>	<u>PASSED</u>	<u>FAILED</u>
<b>WATER</b>	<b>15</b>	<b>YES PASSED</b>	
<b>FOAM</b>	<b>6</b>	<b>YES PASSED</b>	
<b>CO2</b>	<b>15</b>	<b>YES PASSED</b>	
<b>POWDER</b>	<b>14</b>	<b>YES PASSED</b>	
<b>WET CHEMICAL</b>			
<b>FIRE BLANKET</b>	<b>2</b>	<b>YES PASSED</b>	

**ACCOUNT NUMBER 1200                      DATE OF ISSUE 27.01.2020                      SIGNED A ROBINSON**

**DOES CUSTOMER COMPLY WITH CORRECT 26A FIRE RATING ON EACH LEVEL YES OR NO ( YES )**

**NOTE: CUSTOMER IS AWARE ON DRY POWDER ISSUES.**

This Is To Certify That the Fire Extinguishers Have Been Maintained In Accordance With Bs 5306 By A Fia Approved And British Fire Consortium Service Engineer.  
This Is An Annual Maintenance Service And Is Your Proof That The Fire Fighting Equipment Listed On You Certificate Has Been Subject To The Highest Quality Service Possible.  
The Customer Is Required To Do Visual Inspections At Least Once A Month and Contact South East Fire Safety Above If Any Problems Or Corrective Action Is Required Before Next Service.

**South East Fire Safety Limited**

Site office: Unit 3 station estate South Woodford London E18 1BY  
Telephone: 07885 977 005 24 Hours Email: [info@southeastfiresafety.co.uk](mailto:info@southeastfiresafety.co.uk)  
Office hours only Monday - Friday 0208 306 1231  
(Registered office head office) 23 Olron crescent, Bexleyheath Kent DA6 8JY  
Company number 8303857 vat registration number 944 8313 09



Fire Extinguishers, Fire Alarms, Emergency Lights, Risk Assessments



Approved Member